




QUICK INSTALLATION

ML

Excellia M


Hydraulic unit for Monobloc 1 service



Hydraulic unit
024160



U0763834_2482_ML_2
03/04/2024

For professionals.
To be kept by the user for future reference





Electrical case :

A - Main.

B - Heating electrical backup.

9 - Pressure sensor

12 - Circulating pump

14 - Safety valve

22 - Automatic bleeder valve

50 - Expansion vessel

54 - Pressure gauge



145 - Drain valve

210 - Buffer tank

400 - Main supply terminal block



410 - Relay



533 - Electrical backup safety thermostat




■ EXCELLIA M

50 kg













Ø	Tightening torque
1/2"	25 Nm
3/4"	35 Nm
1"	45 Nm
1-1/4"	60 Nm



- 1 - HP inlet (Outdoor unit).
- 2 - HP outlet (Outdoor unit).
- 3 - Sediment trap
- 4 - Heating return (1 circuit).
- 5 - Heating flow (1 circuit).
- 6 - Stop valve (not provided).
- 7 - Evacuation pipe (drainage).





Commissioning date:

Address of your heating installer or customer service.



This equipment complies with:

- Low Voltage Directive 2014/35/EC in accordance with NF EN 60335-1, NF EN 60335-2-40, NF EN 60529, NF EN 60529/A2 (PI) standards,
- Electromechanical Compatibility Directive 2014/30/EC,
- Machines Directive 2006/42/EC,
- Pressure Equipment Directive 2014/68/EC in accordance with NF EN 378-2 standard,
- Ecodesign Directive 2009/125/EC,
- Energy Labelling Directive 2010/30/EC.

This appliance also complies with:

- Decree No. 92-1271 (and its modifications) relating to certain refrigeration fluids used in refrigeration and air conditioning equipment.
- Regulation 842/2006 of the European parliament on certain fluorinated greenhouse gases.
- The standards relating to the product and the testing methods used: Air-conditioners, refrigeration units and heat pumps with compressor driven by electric motor for heating and refrigeration EN 14511-1, 14511-2, 14511-3, and 14511-4.
- Standard EN 12102: Air-conditioners, heat pumps and dehumidifiers with compressor driven by electric motor. Measurement of airborne noise. Determination of acoustic power level.



Keymark Certification :

- 012-C700215- EXCELLIA M 6
- 012-C700216 - EXCELLIA M 8
- 012-C700217 - EXCELLIA M 11



Points de collecte sur www.quefairedemesdechets.fr